



MONTEREY BAY AIR RESOURCES DISTRICT

24580 Silver Cloud Court, Monterey, CA 93940

(831) 647-9411, www.mbard.org

VEEDER ROOT VAPOR POLISHER HC EMISSIONS TEST

Exhibit 12 of ARB E.O. VR 203-X or VR 204-X

| SOURCE INFORMATION | | | TEST COMPANY INFORMATION | | |
|------------------------|-----|---------------------------------|--------------------------|-----|----------------------------------|
| Facility (DBA) Name | | Facility Contact Name and Title | Test Company Name | | Test Company Representative Name |
| Street Address | | | Street Address | | Signature |
| City | Zip | Phone No. | City | Zip | Phone No. |
| District Test Witness: | | Permit Number: | Date of Test: | | ICC Cert. No: |
| | | | Time of Test | | Phase II Manufacturer Cert No: |

| | |
|-----------------|--|
| STEP 6.2 6.3 | CAL GAS DOCUMENTATION ATTACHED? Yes No HC ANALYZER ZERO CHECK READING: _____ HC ANALYZER CAL CHECK READING: _____ IS THE ZERO READING < 1,000 ppm? Yes No IS THE CAL CHECK READING BETWEEN 8,000 and 10,000 ppm? Yes No (IF NO: THE HC ANALYZER MUST BE RE-CALIBRATED.) |
| STEP 6.5 6.6 | 3-WAY VALVE IN CORRECT POSITION (PER FIG. 1)? Yes No PMC VALVE MODE SET TO MANUAL OPEN? Yes No |
| STEP 7.1 | START FLOW RATE: _____ END FLOW RATE: _____ |
| STEP 7.3 | HC READING AT 3 MIN: _____ HC READING AT 4 MIN: _____ HC READING AT 5 MIN: _____ HC READING AT 6 MIN: _____ IS THE HC CONC. < 9,000 ppm FOR ALL READINGS? Yes No (IF NO: THE VR POLISHER IS NOT IN COMPLIANCE WITH THE HC EMISSION REQUIREMENTS OF EXHIBIT 2.) |
| STEP 7.5 | 3-WAY VALVE SET TO NORMAL OPEN POSITION? Yes No (UST Ullage to Vapor Polisher) RE-SET VAPOR VALVE TO AUTOMATIC MODE? Yes No |